Column & Fire Equipment Guidelines	Booth 10922
Please be aware of building support columns with fire equipment in or around your booth space. General booth guidelines can be found here: https://www.namm.org/exhibit/thenammshow/important-guidelines/display-guidelines-rules-regulations NOTE: Fire equipment must be visable and accessible at all times	
2'-4" 9'-10" 20' E 10922 FE-FS 20' 20'	5'-6"
<u>FS (Fire Strobe)</u> : Located at 20' height; Hall E are 12' height from the floor; ACC lobbies are 6'7" height from the floor. <u>FE (Fire Extinguisher)</u> : Must remain visible, accessible and unobstructed <u>SP (Fire Speaker)</u> : 6"x6" & located at 9'9" height from the floor and shall be visible and unobstructed <u>FHC (Fire Hose Connection)</u> : Must remain visible, accessible and unobstructed FDR (Facility Door Release): Must not be blocked	Building Support Column Exhibitors are free to brand & build around columns, as long as fire equipment is clear and nothing is adhered to the column or physical building.
 PLEASE NOTE: This diagram indicates the size and approximate position of the obstruction within the booth with measurements. This may vary slightly onsite once the floor has been marked All fire equipment on columns must remain visible and accessible at all times and fire hoses must be clear to the aisle. Fire alarm devices have a strobe and a speaker at two different heights on a column Materials may not be affixed to columns; damage will be billed back to the exhibitor by the Anaheim Convention Center. 	