Column & Fire Equipment Guidel	ines		Booth 1716
Please be aware of building support columns with fire equipment in or around your booth space. General booth guidelines can be found here: https://www.namm.org/exhibit/thenammshow/important-guidelines/display-guidelines-rules-regulations NOTE: Fire equipment must be visable and accessible at all times			
2'	^{8'} 2' 1718	1818	
18'	20'	20'	
_	1716	1816	
REFERENCE GUIDELINES (unless otherise noted on map) <u>FS (Fire Strobe)</u> : Located at 20' height; Hall E are 12' height from the floor; ACC lobbies are 6'7" height from the floor. <u>FE (Fire Extinguisher)</u> : Must remain visible, accessible and unobstructed <u>SP (Fire Speaker)</u> : 6"x6" & located at 9'9" height from the floor and shall be visible and unobstructed <u>FHC (Fire Hose Connection)</u> : Must remain visible, accessible and unobstructed FDR (Facility Door Release): Must not be blocked Building Support Column Exhibitors are free to brand & build around columns, as long as fire equipment is clear and nothing is adhered to the column or physical building.			
 measurements. This may vary sligl All fire equipment on columns must clear to the aisle. Fire alarm devices have a strobe an Materials may not be affixed to colum Convention Center. 		re hoses must be	