Column & Fire Equipment Guidelines	Booth 5238
Please be aware of building support columns with fire equipment in or around your booth space. General booth guidelines can be found here: https://www.namm.org/exhibit/thenammshow/important-guidelines/display-guidelines-rules-regulations NOTE: Fire equipment must be visable and accessible at all times	
30 31'-10" 5238	- <b>FS</b> -11"
REFERENCE GUIDELINES (unless otherise noted on map)       Image: Building Support are 6'7' height from the floor; ACC lobbies are 6'7' height from the floor.         FE (Fire Extinguisher): Must remain visible, accessible and unobstructed       Building Support Exhibitors are free to be columns, as long as fire and unobstructed         SP (Fire Speaker): 6"x6" & located at 9'9" height from the floor and shall be visible and unobstructed       Building Support Exhibitors are free to be columns, as long as fire and nothing is adhered physical building.         FHC (Fire Hose Connection): Must remain visible, accessible and unobstructed FDR (Facility Door Release): Must not be blocked       Private Point Po	rand & build around e equipment is clear
<ul> <li>PLEASE NOTE:</li> <li>This diagram indicates the size and approximate position of the obstruction within the booth with measurements. This may vary slightly onsite once the floor has been marked</li> <li>All fire equipment on columns must remain visible and accessible at all times and fire hoses must be clear to the aisle.</li> <li>Fire alarm devices have a strobe and a speaker at two different heights on a column</li> <li>Materials may not be affixed to columns; damage will be billed back to the exhibitor by the Anaheim Convention Center.</li> </ul>	